



Title/Description:		
BID BULLETIN No. 1 (as of July 30, 2015)		
Transaction:		
“One (1) Lot Supply, Installation and Commissioning of Airconditioning Units at 5/B Floor in DAP Building, Pasig City”		
Bidding Number:	ABC for the Project:	Office of the End-User
IB NO. 15-367113-03	P1,200,000.⁰⁰	Center for Office and Conference Facilities (COCF)

This has reference to the discussions and agreements made during the Pre-Bid Conference conducted on 24 July 2015 (Friday), 10:00AM at the 3B/F, Rizal Honor Hall of the **dap** Bldg in San Miguel Ave., Pasig City by the Bids and Awards Committee (BAC) for the procurement of **“One (1) Lot Supply, Installation and Commissioning of Airconditioning Units at 5/B Floor in DAP Building, Pasig City”**. The following are being considered clarifications and/or modifications of the Official Bid Documents (OBD):

1. *The Letter of Authorization (LOA) shall be presented by any Bidder’s Representative during the submission of Bids and must be signed by the same person who will sign the Contract for the said transaction. The said LOA should be separated from the Sealed Bid, and must be readily available for scrutiny of the DAP-BAC; preferably pasted on the ‘biggest envelope’ of the bids.*

2. *The Item 2.2 on page 62 of Section VII. Technical Specifications of the OBD shall be read as follows:*
 - 2.2 Supply, Installation and Commissioning of New Two (2) Units Inverter-type, 2.0-hp Window type Airconditioning Units at 5/B Office of the Managing Director and Conference Room:

- Deliver the two(2) units window type AC 2.0-hp inverter type for approval, specifications below;
 - (A) Inverter type 2.0-hp Window type(indoor color white);
 - (B) 230V, 60Hz, Single Phase; and,
 - (C) With remote control.
- Cut the glass window and install framing and support for AC unit at OMD CQC and CQC conference room;
- Install drain pipes;
- Install electrical feeder line and WACU power outlet from the unit through main electrical AC power panel at AHU 5B/F; and,
- Test- run and commission the unit.

